



LPG Certificate

Cert No.
No. 0248
No. Appliances
2

Registered Business/engineer details can be checked at www.gassaferegister.co.uk or by calling 0800 408 5500

Company / Installer		Inspection / Installation Address			Landlord / Agent / Customer		
Engineer	Steve Smith	Name	Mrs Edwards		Name	James Cox	
Company	Phoenix EP Services Ltd	Address	A012 Highlands End Holiday Park Eype Dorset		Company Name	West Dorset Leisure Holidays	
Address	Unit 7 Hounsell Building, North Mills T/Estate, Bridport. Dorset. DT6 3BE.	Postcode	DT6 6AR		Address	Highlands End Holiday Park Eype Bridport Dorset	
Tel No.	01308458619	Mobile			Postcode	DT6 6AR	
Gas Safe Reg.	622518	Email			Email	andrew.mcleary@wdlh.co.uk	
ID Card No.	5524297	Unique Property Reference Number			Phone		
Email	steve@phoenixepservices.com				Unique Property Reference Number		

Appliance Details					Inspection Details																									
#	Location	Appliance Type	Make	Model	Flue Type	Serial No.	Appliance Inspected	Operating Pressure mBar	Heat Input kW/h	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use	CO alarm fitted	CO alarm in date	CO alarm Satisfactory						
										Ratio	CO ppm	CO ₂ (%)	Ratio	CO ppm	CO ₂ (%)															
1	Kitchen	Cooker	THETFORD	ENIGMA	FL		Yes	36	12						Yes	Yes	N/A	N/A	No	Yes	Yes	Yes	Yes							
2	Hall	Combination Boiler	MORCO	GB 24 SERIES 3	FF		Yes	36	24	.0004	75	8.99			Yes	N/A	Yes	Pass	No	Yes	Yes	Yes	Yes							
3																														
4																														
5																														

Defects Identified	Remedial Action	Warning Notice Issued	Warning Notice Serial No
		N/A N/A	

Cylinder/final connection hoses to LAV/boat Satisfactory	Gas Tightness Satisfactory	Gas installation pipework visual inspection satisfactory	ECV accessible and operable	LPG regulator operation pressure (mBar)	LPG regulator lock-up pressure (mBar)	Landlord Appliance
No	Yes	Yes	Yes	36	55	Yes

Comments
-

Signatures			
Signed		Received By	Date
Print Name	Steve Smith	Print Name	05/06/2024
		N/A	Next Inspection Date
			05/06/2025